

The Chief Officer,
Margao Municipal Council,
Margao- Goa.

NO OBJECTION CERTIFICATE

Report of Health Officer from Sanitation Point of View for the proposed Construction of building A & B and Construction of compound wall in Chalta No: 8 (old) & 40 (new) of P.T.S. No. 132, Ref: SGPDA/P/ 6043/855/18-19 dated 31/08/2018. Ref Application No 1024 Dtd: 17/09/2018 of M/s Madanant Construction Pvt. Ltd & Mr. Vibhav Parkar, Borda, Margao Goa. This is to certify that the Health Officer along with the Sanitary Inspector has inspected the site of the proposed Construction of building & Amalgamation of properties in Chalta No: 8 (old) & 40 (new) of P.T.S. No. 132 at Gogol, Margao Goa. and this office No Objection for the construction from the sanitary point of view as under:-

- a) No. of unit for residential:- **2** Proposed construction of Building A and B at
b) No. of unit for commercial:- **2** Gogol Margao-
c) Total:-
d) Size of the septic tank & soak pit :- **To connect sewerage line eastern side**
for the above person.
e) Whether the septic tank Soak pit :- **Yes eastern side**
has been shown on the plan. So at
which site
f) Whether the size of the Septic tank :- **Yes 67 person**
Soak pit is adequate to the above
unit and persons. if not what should
be the size
g) Whether the drains in the complex:- **Yes**
have been properly shown to discharge
of rain water
h) Whether there is any possibility of :- **Yes**
contaminating the water by the near
by wells due to the construction of
septic tank Soak pit.

The Applicant Builder shall further observe the following conditions: -

- 1) The Applicant Builder should ensure that all the labourers posses cards and the same should be renewed every three months. No labour shall be engaged by the Contractor Builder at the construction sites unless he/she has a Health Card.
- 2) The soak pit of the septic tank should be constructed at minimum distance of 15.00meters away from any well whose water is used for domestic purpose or for providing water.
- 3) The N.O.C. shall be revoked if the construction of the Septic tank/ Soak pit drainage system of the building is not existing as per the approved plans.
- 4) The Applicant should construct a separate soak pit in order to absorb in the sullage water from Kitchen and other non sewage sources.
- 5) Accumulation of water shall be prevented in pits in around the site so as to avoid breeding of Mosquitoes.
- 6) The Builder/ Contractor etc. to take adequate anti- larval measures at to construction sites in consultation with the concerned Health officer.
- 7) N.O.C. from this Authority be obtained before issuing Occupancy Certificate.
- 8) The N.O.C. Certificate issued is liable to be withdrawn if conditions stipulated above are not complied with.
- 9) Temephos (Abate Nolar) mixing proportion 2.5ml in 10 lit of water to be sprayed once in 7 days.
- 10) Board should be displayed with builder name & contact no., Municipal License No. / Health NOC No., SPDA Order/ License No.

Note: At the time of inspection before Health Officer issued the construction of existing house at above address was completed.



Ammaezel
Health Officer.

HEALTH OFFICER
URBAN HEALTH CENTRE
MARGAO

Copy to:

1. M/s Madanant Construction Pvt. Ltd & Mr. Vibhav Parkar, Borda, Margao Goa
2. Dy. Labour Commissioner, South Goa.