



GOVERNMENT OF GOA  
DIRECTORATE OF HEALTH SERVICES  
URBAN HEALTH CENTRE - PANAJI

Panaji-Tiswadi Goa.

Tel./ Fax :- (0832) 2426495 , Email :uhcpanaji@gmail.com

No.UHCP/DHS/NOC/19-20/3222

Date:- 08/02/2020

**NO OBJECTION CERTIFICATE**

This is to certify that I /My representative have /has inspected site of the Proposed - construction of existing commercial building by **Mr Mario B.Fernandes**, bearing **chalta no. 54 of P.T.sheet no.143**, situated at **Miramar Panaji -Goa** and I have no objection to the said construction from the sanitary point of view as under:-


Approximate No. of persons:-100

a)	No. of Units for Residential purpose:	16		
b)	No. of units for commercial purpose	4		
c)	Total;	20		
d)	Size of the septic tank & soak pit for the above person	L.	B.	Volume
		Sewage connection		
e)	Whether the <b>sewerage lines/STP /ST/SP</b> ,has been shown on the plan & if so, which side.	Yes,		
f)	Whether the Soak pit /Septic tank is adequate to the above units/persons and if not what should be done	NA		
g)	Distance of the Soak pit /Septic Tank /STP from any drinking water well	NA		
h)	Whether the drains in the complex have been properly shown to discharge rain water	Yes		
i)	Whether there is any possibility of contaminating water in the nearby wells due to construction of septic tank and soak pit:	NA		

**This NOC is issued on the condition that the applicant and /or builder shall observe the following requirements:**

- 1 The soak pit should not be located within a distance of 15.00 meters from any other existing well in the plot area/ plan.
- 2 All the labourers employed in the construction activity shall possess valid Health Cards and the same shall be renewed every three months. NO labourers shall be engaged by the Builder/Contractor unless he/she has a valid Health Card,whoever contravenes the above provision of the Health Act shall be Punishable with fine of 10,000 ,per labour as specified in the Act.
- 3 The NOC shall be revoked if the construction of the Septic tank, Soak pit and Drainage system of the premises are not as per the approved plan.
- 4 The applicant shall construct a separate soak pit in order to absorb the sewage water from the kitchen and from other non sewage resources.
- 5 Accumulation of water shall be prevented in pits in and around the site so as to avoid the breeding of mosquitoes.
- 6 The builder/contractor shall take adequate anti-larval measures at the construction site in consultation with the Health Officer/Medical Officer I/c or Sanitary Inspector
- 7 NOC from the authority shall be obtained before obtaining the Occupancy Certificate.
- 8 The sanitary toilets have to be provided to all labourers residing at the construction site.
- 9 The NOC is liable to be withdrawn if the conditions stipulated above are not complied with or if it is established that this NOC has been obtained using fraudulent means.
- 10 Construction board with details should be displayed at the construction site.

Yours faithfully

  
(Dr. Neeta Kakodkar )  
Health Officer

Urban Health Centre, Panaji

To,

Mr Mario B.Fernandes  
Dynasty Manor,Vodlem bhat ,  
Taleigao-Goa

Copy to:-

- 1.The Municipal Engineer,Corporation of the city of Panaji-Goa
- 2.Office Copy