

This NOC is issued on the condition that the applicant and / or builder shall observe the following requirements :-


- The soak pit and the septic tank shall be constructed at a minimum distance of fifteen meters away from any drinking water well.
- All the labourers employed in the construction activity shall possess valid Health Cards and the same shall be renewed every three months. No laborers shall be engaged by the Builder / Contractor unless he / she has a valid Health Card.
- The NOC shall be revoked if the construction of the septic tank soak pit and drainage system of the building are not as per the approved plan.
- The applicant shall construct a separate soak pit in order to absorb the sewage water from the kitchen and from other non sewage resources.
- Accumulation of water shall be prevented in pits in and around the site so as to avoid the breeding of mosquitoes.
- The builder / contractor shall take adequate anti - larval measures at the construction site in consultation with the Health Officer / Medical Officer i / c or Sanitary Inspector.
- NOC from this authority shall be obtained before obtaining the Occupancy Certificate.
- The Sanitary toilets have to be provided to all labourers residing at the construction site.
- This NOC is liable to be withdrawn if the conditions stipulated above are not complied with or if it is established that this NOC has been obtained using fraudulent means.
- Construction board with details should be displayed at the construction site.


Health Officer
Primary Health Centre
Cansaulim - Goa

To,

**The Sarpanch
Village Panchayat
Velsao - Pale-Issorcim.
Mormugao Goa.**

Copy

 **Mr. Agnelo Alcasoas,
Queeny Nagar
Pale- Goa.**

Government of Goa
Directorate of Health Services
PRIMARY HEALTH CENTRE
Cansaulim -Goa

No.PHCC/Cans/NOC/15-16/ 1199

Date : 22/12/15

NO OBJECTION CERTIFICATE

This is to certify that Health Officer & Sanitary Inspector of Primary Health Centre, Cansaulim has inspected the site on 22/12/2015 of the proposed construction of Residential Villas at Survey No 51/4 at Pale Village of Mr. Agnelo Alcasoas Queeny Nagar Pale (Reference No. DH/5124/4/MTP/15/1175 dated 16/12/2015) and this office has **No Objection to the said construction from the sanitation point of view as under:**

Approximate No. of persons 50

- ✓ No. of units for residential purpose 07
- ✓ No. of units for commercial purpose Nil
- ✓ Total 07
- ✓ Size of the septic tank & soak pit for the above persons As per Plan attached
- ✓ Whether the septic tank & soak pit has been shown on the plan & if so, on which side West Side
- ✓ Whether the size of the septic tank / soak pit is adequate to the above units / persons and if not what should be done Yes
- ✓ Distance of the septic tank / soak pit from any drinking water well No Well.
- ✓ Whether the drains in the complex have been properly shown to discharge rain water Yes
- ✓ Whether there is any possibility of contaminating water in the nearby wells due to construction of septic tank and soak pit No