



GOVERNMENT OF GOA
DIRECTORATE OF HEALTH SERVICES
PRIMARY HEALTH CENTRE, CANDOLIM - GOA
Phone:(0832) 2489035.

No: PHCC/N.O.C./2017-18/3569

DATE: 10/01/2018

To,
Mr Amit Talwar,
C/o. Sainath Patekar
F-3, Anandvan Apartment
Nr. Old Asilo Hospital,
Mapusa Bardez Goa.

Sub: N.O.C. for Construction.

Sir,

With reference to the your letter No. Nil dated 12/12/2017 and with reference to Development Permission order issued by the North Goa Planning and Development Authority bearing No. NGPDA/CAL/44/218/1445/17 dt. 17/03/2017, site inspection was conducted by this office on 18/12/2017, in this regards, I am to inform you that there is NO OBJECTION FROM SANITARY POINT OF VIEW for proposed Construction of Residential building, Compound Wall & Swimming Pool in Sy. No 442/2 Situated at Calangute, Bardez – Goa, by Mr Amit Talwar, subject to the following conditions.

1. The construction is carried out as per the plan submitted.
2. Proper cleanliness is maintained in and around the construction site.
3. The soak pit and septic tank should be at least fifteen meters away from any drinking water source of neighboring plot and should correspond with the dimensions given.
4. The capacity of the septic tanks/STP should correspond with dimensions shown in the chart submitted to this office for 50 persons.
5. No health hazard or any other environmental pollution is created in the surrounding area.
6. The owner/contractor shall co-operate with the health and pollution control authorities whenever they visit the site for sanitary inspection.
7. This office is not responsible for any court litigation regarding the ownership and area of the hotel building.
8. If any complaint comes from the sanitary point, the N.O.C. will be revoked.
9. As per section 75A of Goa Public Health Act all labourers should posses health cards and should renew them once in three months. Whoever contravenes the provision of the health Act, shall be punishable with fine as specified in the Act.
10. Health cards should be available at the site and should be produced to the Health Staff on demand.
11. Final N.O.C. from Health Authorities to be obtained prior to issuance of occupancy certificate.
12. The N.O.C. is liable to be withdrawn if the conditions stipulated above are not complied with.
13. The soak pit and septic tank to be shifted as per the affidavit submitted no 844/2018.



Yours faithfully,

(Signature)

(Dr. J.B.P. Furtado Pinto)

Health Officer

Primary Health Centre, Candolim