

No. UHC/ NOC/ 19-20/ 2012

The Chief Officer,
Margao Municipal Council,
Margao- Goa.

NO OBJECTION CERTIFICATE

Report of Health Officer from Sanitation Point of View for the Construction of building in Chalta No: 15 of P.T.S. No. 44, Ref: SGPDA/P/ 6241/1353/19-20 dated 13/12/2019. Ref Application No 1960 Dtd: 23/12/2019 of Mrs. Tabassum Parveen Ali & Mr. Mohammed Bakkar Ali, Plot No. H-16, Vasant Nagar, Gogol, Margao- Goa. This is to certify that the Health Officer along with the Sanitary Inspector has inspected the site of the Construction of building in Chalta No: 15 of P.T.S. No. 44 at Fatorda, Margao-Goa. and this office No Objection for the construction from the sanitary point of view as under:-

- Proposed construction of building*
- No. of unit for residential:-
 - No. of unit for commercial:-
 - Total:- *17 units.*
 - Size of the septic tank & soak pit :-
for the above person.
 - Whether the septic tank/Soak pit :-
has been shown on the plan. So at
which site
 - Whether the size of the Septic tank/ :-
Soak pit is adequate to the above
unit and persons, if not what should
be the size } *Bldg sewage to be connected in public
Sewer line*
 - Whether the drains in the complex:-
have been properly shown to discharge
of rain water *Yes*
 - Whether there is any possibility of :-
contaminating the water by the near
by wells due to the construction of
septic tank Soak pit. *No*

The Applicant/ Builder shall further observe the following conditions: -

- The Applicant/ Builder should ensure that all the labourers possess cards and the same should be renewed every three months. No labour shall be engaged by the Contractor/ Builder at the construction sites unless he/she has a Health Card.
- The soak pit of the septic tank should be constructed at minimum distance of 15.00 meters away from any well, whose water is used for domestic purpose or for providing water.
- The N.O.C. shall be revoked if the construction of the Septic tank/ Soak pit drainage system of the building as not existing as per the approved plans.
- The Applicant should construct a separate soak pit in order to absorb in the sullage water from Kitchen and other non sewage sources.
- Accumulation of water shall be prevented in pits in around the site so as to avoid breeding of Mosquitoes.
- The Builder/ Contractor etc. to take adequate anti- larval measures at to construction sites in consultation with the concerned Health officer.
- N.O.C. from this Authority be obtained before issuing Occupancy Certificate.
- The N.O.C. Certificate issued is liable to be withdrawn if conditions stipulated above are not complied with.
- Temephos (Abate/Nolar) mixing proportion 2.5ml in 10 lit of water to be sprayed once in 7 days.
- Board should be displayed with builder name & contact no., Municipal License No. / Health NOC No., SPDA Order/ License No.



Akshay
Health Officer,
HEALTH OFFICER
URBAN HEALTH CENTRE
MARGAO

Copy to,

- Mrs. Tabassum Parveen Ali & Mr. Mohammed Bakkar Ali, Plot No. H-16, Vasant Nagar, Gogol, Margao- Goa.
- Dy. Labour Commissioner, South Goa.